

# Evidence of Performance

Burglar resistance

## Test Report

Nr. 16-000109-PR01

(PB-A01-05-en-01)



Client	ORAMA LTD German Road 20300 Loutraki Greece
Product	Burglar resistant sliding window RC2
Designation	ORAMA Omicron
Overall dimensions (W x H)	2250 mm x 2250 mm
(Frame) Material, System	Aluminium profiles with thermal break
Attack side	Outside of building
Type of opening	Slide
Glazing	P6B as per EN 356 1083 set / Orama Omicron Sliding system with 2 bogies, 2 locks and lockable handle
Hardware	
Installation	As set out in the installation manual by the client Orama LTD
Special features	-/-

### Basis

DIN EN 1627 : 2011  
Pedestrian doorsets, windows, curtain walling, grilles and shutters – Burglar resistance – Requirements and classification

DIN EN 1628 : 2011

DIN EN 1629 : 2011

DIN EN 1630 : 2011

### Representation



### Instructions for use

This test report serves to demonstrate the burglar resistance

### Validity

The data and results refer solely to the tested and described specimen. The burglar resistance test does not allow any statement to be made on any further characteristics of the present structure regarding performance and quality.

In deviation from the tested design the following size modifications are permitted:  
in width +10% and -20%  
in height +10% and -20%

## Burglar resistance



RC 2 / RC 2 N

ift Rosenheim

09.08.2016

Konrad Querengässer, Dipl.-Ing. (FH)  
Head of Testing Department  
Security/Safety Testing

Florian Willer, Dipl.-Ing. (FH)  
operating testing officer  
Security/Safety Testing

### Notes on publication

The ift- Guidance Sheet "Conditions and Guidance for the Use of ift Test Documents" applies.

The cover sheet can be used as an abstract.

### Contents

The report contains a total of 44 pages

- 1 Object
- 2 Procedure
- 3 Detailed results  
Annex 1 (21 pages)  
Annex 2 (4 pages)  
Annex 3 (5 pages)